



Fillmore County Highway Department

909 Houston Street NW, Preston, MN 55965

(P) (507) 765-3854
(F) (507) 765-4476

RONALD GREGG, P.E.
COUNTY ENGINEER

BRENT KOHN
MAINTENANCE SUPERINTENDENT

December 11, 2017

ADDENDUM NO. 1

To: Plan Holders

From: Ronald Gregg PE, Project Engineer

Project No.: SAP 023-601-034 and SAP 055-601-021

Clarifications:

- Whereas:** Note on page 3 of 16 reads- Transverse contraction joints shall be type C1U-D spaced at a 15' interval.
Shall be: Transverse contraction joints shall be type C2H-D spaced at a 15' interval.
- Structural Rumble Strip placement either ground or floated shall be incidental to the Concrete Paving.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ronald Gregg", is written over a faint circular stamp.

Ronald Gregg PE, Fillmore County Engineer
507-765-3854
rgregg@co.fillmore.mn.us